



Date Submitted: 1/17/2025

Water Use Efficiency Annual Performance Report – YEAR END 2024

WS Name: MORTON CITY OF Water System ID# : 56250 WS County: LEWIS

Report submitted by: *Damon Stevens*

Meter Installation Information:

Estimate the percentage of metered connections: *100%*

If not 100% metered – Did you submit a meter installation plan to DOH? *No*

Within your meter installation plan, what date did you commit to completing meter installation?

Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period *01/01/2024* To *12/31/2024*

Incomplete or missing data for the year? *No*

If yes, explain:

Total Water Produced & Purchased (TP) – Annual volume gallons	<i>70,563,000</i>	
Authorized Consumption (AC) – Annual Volume in gallons	<i>55,512,821</i>	gallons
Distribution System Leakage – Annual Volume TP – AC	<i>15,050,179</i>	gallons
Distribution System Leakage – DSL = [(TP – AC) / TP] x 100 %	<i>21.3 %</i>	
3-year annual average - %	<i>26.2 %</i>	<i>2022, 2023, 2024</i>

Goal-Setting Information:

Enter the date of most recent public forum to establish WUE goal: *11/26/2018*

Has goal been changed since last performance report? *No*

Note: Customer goal must be re-established every 6 years through a public process.

Customer WUE Goal (Demand Side):

Proposed to city council on 11/26/2018, continue resolution of consumer water savings of 5% over the next 6 years